



产品认证证书

证书编号：CQC18012185494

申请人名称及地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

制造商名称及地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

生产企业名称及地址

浙江天正电气股份有限公司(V024163)
浙江省乐清市柳市镇柳乐路 332 号

产品名称和系列、规格、型号

自恢复式过欠压保护器

TGZGQ3-80; Ui: 500V; Ue: AC230V; In: 20A,25A,32A,40A,50A,63A,80A; 额定限制短路电流能力 (Inc): 6kA; 极数: 1P+N(1 个保护极,N 极常通,不适用于隔离);不带过电流保护

产品标准和技术要求

JB/T12762-2015

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC11-462188-2016 认证规则的要求，特发此证。

发证日期：2018 年 01 月 04 日

本证书的有效性依据发证机构的定期监督获得保持。

主任：_____ 

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC18012185494

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Tengen Electrics Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Tengen Electrics Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Zhejiang Tengen Electrics Co.,Ltd. (V024163)
No.332 Liule Road, LiuShi Town, Yueqing City, Zhejiang Province

PRODUCT NAME, MODEL AND SPECIFICATION

overvoltage or undervoltage protective device with auto-reclosing function (OUPA)
TGZGQ3-80; Ui: 500V; Ue: AC230V; In: 20A,25A,32A,40A,50A,63A,80A; Inc:6kA; Poles: 1P+N(1protected pole,with uninterrupted N pole,not used for disconnection);without over-current protection

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

JB/T12762-2015

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462188-2016 .

Valid from: Jan.04,2018

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

President: _____

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>